

February 27, 2003

Mr. Barry Gardner  
Shelco, Inc.  
3120 Highwoods Blvd./Ste 100  
Raleigh, NC 27604

RE: Agenda for the March 10, 2003 Public Hearing  
Agenda for the March 11, 2003 Building Code Council Meeting

Dear Barry:

This is to officially notify you and other interested parties of a regularly scheduled meeting of the Building Code Councils

1. The work session will begin at 9:00am on March 10, 2003. The work session is open to the public on a non-contributing basis.
2. The Administrative Committee will meet immediately following the work session.
3. The Mechanical Committee will meet immediately following the Administrative Committee meeting.
4. The public hearings will begin at 1:00pm on March 10, 2003.
5. The Building Code Council meeting will begin at 9:00am, March 11, 2003.

All meetings will be held at the Wake County Commons located at 4011 Cary Drive, Raleigh, NC 27610. Persons requiring auxiliary aid or service should notify the Council at least (10) working days prior to the meeting.

**ITEM 1 - APPROVAL OF MINUTES OF THE DECEMBER 11, 2002, BUILDING CODE COUNCIL MEETING.**

**ITEM 2 - REQUEST BY TOWN OF APEX FOR AUTHORITY TO REVIEW PLANS AND SPECIFICATIONS FOR BUILDINGS AS LISTED IN TABLE 502 OF THE NORTH CAROLINA ADMINISTRATION AND ENFORCEMENT CODE.**

**ITEM 3 - EVALUATION OF STATEMENT OF ECONOMIC INTEREST FILED BY BARRY MANESS.**

**ITEM 4 - APPEAL BY HELMS, MULLIS & WICKER, PLLC OF THE INTERPRETATION ISSUED BY GROVER SAWYER FOR THE REQUIREMENT TO PROVIDE ASSISTIVE LISTENING DEVICES.**

**ITEM 5 - APPEAL BY GARY FITTS, ASSISTANT FIRE MARSHAL, WINSTON SALEM FIRE DEPARTMENT OF THE INTERPRETATION ISSUED BY GROVER SAWYER THAT A SPRAY BOOTH IS NOT REQUIRED FOR SPRAYING OF URETHANE BODY LINING MATERIAL**

**PETITIONS FOR RULEMAKING**

The Secretary has received the following petitions for rulemaking. The Council will vote to grant or deny the petitions. Petitions that are granted may proceed through the rulemaking process. The Council will give no further consideration to petitions that are denied. The Council may send any petition to the appropriate committee for review. Committee meetings are scheduled for June 9, 2003, if needed. The public hearing for petitions granted at March meeting will be held on September 8, 2003.

**ITEM 6 - REQUEST BY F. REED JARVIS TO REVISE SECTION 106 TO THE 2002 NORTH CAROLINA FIRE PREVENTION CODE AS FOLLOWS:**

Section 106: Modify the Inspection Schedule only. All other portions remain unchanged.

Once every year	Hazardous, Institutional, HighRise, Assembly <u>except those noted below</u> and Residential except one and two family dwellings and only interior common areas of dwelling units of multi-family occupancies
Once every two years	Industrial and Educational (Except public schools)
Once every three years	Business, Mercantile, Storage, Churches <del>and</del> , Synagogues <u>and Assembly with an occupant load less than 100.</u>

**PUBLIC HEARING AND FINAL ADOPTION**

Items 15 and 16 are on the agenda for final approval by the Council. A public hearing was held March 10, 2003, for the public to provide comments concerning the proposals. Items approved by the Council will go to the Rules Review Commission for approval. The Council will give no further consideration to items that are denied. Upon approval by the Rules Review Commission, the rules will await possible action by the NC Legislature.

**ITEM 7 - REQUEST BY F. REED JARVIS OF NC FIRE SERVICE CODE REVISION COMMITTEE TO REVISE SECTION 907.2.3 OF THE NORTH CAROLINA FIRE PREVENTION CODE AS FOLLOWS:**

**Exceptions:**

1. ~~Deleted.~~ Group E occupancies with an occupant load of less than 50.

**ITEM 8 – REQUEST BY TIM LAUGHLIN OF NC PETROLEUM MARKETERS ASSOCIATION  
TO REPLACE SECTION 2206.2.3, # 2 OF THE NORTH CAROLINA FIRE  
PREVENTION CODE AS FOLLOWS:**

2. Fleet Vehicle Service Stations:  
When approved by the code official, aboveground storage tanks, 1,100 gallons or less in capacity, may be used to store Class I liquids at fleet vehicle service stations in accordance with NFPA 30A.

Renumber the remaining numbers.

**ITEM 9 - COMMITTEE REPORTS**

**BUILDING CODE COUNCIL COMMITTEES**

1. **ADMINISTRATION CODE COMMITTEE**
2. **MECHANICAL CODE COMMITTEE**

**COMMENTARY COMMITTEES**

1. **PLUMBING CODE COMMENTARY**
2. **MECHANICAL CODE COMMENTARY**
3. **RESIDENTIAL CODE COMMENTARY**

**AD HOC COMMITTEES REVIEWING THE INTERNATIONAL SUPPLEMENTS**

1. **BUILDING CODE**
2. **FIRE PREVENTION CODE**

**ITEM 10- OTHER ITEMS**

Sincerely,

Wanda D. Edwards, PE  
Secretary