

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

ASHRAE Standard for Energy Code Compliance

Code: 2002 Energy Code

Date: September 15, 2004

Section: Section 701.1

Question:

What edition of the ASHRAE Standard 90.1 must be used to demonstrate compliance with Chapter 7 of the 2002 NC Energy Code?

Answer:

Section 701.1 requires compliance with ASHRAE 90.1 except for buildings that comply with Chapter 8. Chapter 9 "Reference Standards" indicates that the edition of the standard is the 1999 edition. The 2001 version may be allowed as an alternate method by the local official having jurisdiction. The 1989 version is outdated and not appropriate to be used to show compliance with the 2002 NC Energy Code.

Keywords:

energy compliance