

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**Automatic and Manual Fire Alarms**

**Code:** 2002 North Fire Prevention Code  
**Section:** 907.1

**Date:** May 2005

**Question:**

What is the difference between a manual fire alarm system and an automatic fire alarm system?

**Answer:**

A majority of traditional alarm systems consist of the alarm notification devices and an alarm panel. These two components are designed and installed in accordance with NFPA 72 with the ultimate purpose of sounding an evacuation signal to instruct the occupants to leave the building.

The difference between manual and automatic fire alarm system is the method to how the panel, and subsequently the alarm notification devices are activated. A manual system is intended to be limited to the pull stations, unless otherwise indicated within the code.

Only when there is a specific reference to smoke detector, such as the requirement for Group I occupancies in Section 907.2.6 are they required by the fire code.