

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**High-Piled Combustible Storage Area**

**Code:** 2002 Fire Prevention Code

**Date:** August 19, 2004

**Section:** Table 2306.2

**Question:**

Is the size of the "high-piled storage area" the area used for the racks or the overall size of the room?

**Answer:**

The answer, defined in Section 2302, is the area designated, intended, proposed or actually used for high-piled storage.

It should be noted that there are conditions, such as movable racks or engineering analysis in accordance with Section 2304.2, that requires the size of the room to be considered for Table 2306.2.