

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**Travel Distance to Gas Fired Equipment in a Crawl Space**

**Code:** 2006 Fuel Gas Code

**Date:** July 1, 2006

**Section:** 306.4

**Question:**

Can the travel distance to gas fired equipment in a crawl space exceed 20 feet when the access opening and passageway is not less than 6 feet high for its entire length ?

**Answer:**

Yes, Section 306.4, Exception 2 allows a 6 foot high passageway in a crawlspace to be unlimited in length.