

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Cast Iron Fittings for Steel or Wrought-iron Gas Piping

Code: 2006 Fuel Gas Code

Date: July 1, 2006

Section: 403.10.4

Question:

Can cast iron fittings be used for steel or wrought-iron gas piping?

Answer:

Yes, cast iron fittings of sizes 4 inches and smaller may be used for steel and wrought-iron gas piping.