

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Domestic Clothes Dryers Exhaust Termination

Code: 2006 Fuel Gas Code
Section: 614.4

Date: July 1, 2006

Question:

What is the required height above finished grade for a domestic clothes dryer exhaust termination?

Answer:

Section 614.4 of the 2006 NC Fuel Gas Code does not directly identify a minimum termination requirement above grade for domestic clothes dryer exhaust caps. Manufacturer's instructions typically require a minimum termination of 12 inches above grade.