

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**Code and Standard Conflicts**

**Code:** 2009 Fire Prevention Code

**Date:** July 1, 2009

**Section:** 102.6

**Question:**

If a North Carolina Fire Prevention Code requirement conflicts with a referenced standard requirement, which one is enforced?

**Answer:**

In accordance with Section 102.6, the 2006 NC Fire Prevention Code is enforced when a conflict occurs between the Fire Prevention Code and a referenced standard. It should be noted that there are requirements where the Fire Prevention Code is amended to change how the referenced standard is enforced.

For example, Section 1208.2 of the NC Fire Prevention Code requires a sprinkler system for Type III-A dry cleaning facilities, however Section 6-1.3.3 of NFPA 32-00 provides an exception for eliminating sprinkler requirements. It is the intent of the NC Fire Prevention Code to amend the referenced NFPA 32 to continue to require sprinklers within a Type III-A dry cleaning facility.